

Andre R. Parent
Chief of Department



Matthew A. K. Lamothe
Assistant Chief

City of Manchester *Fire Department*

Press Release
December 11, 2021

Incident Type: Building Fire

Address: 238 Pearl St

Dispatch: 07:42am

Under Control: 08:19am

Resources:	<u>Engines</u>	<u>Trucks</u>	<u>RIC Engines</u>	<u>Rescue</u>	<u>EMS</u>	<u>Battalion Chief</u>
	11,10,5	1,6	6, 4	R1	ALS-1	Car 1

Description of Incident:

The fire started in the ceiling of the second floor bathroom in the area of the vent fan/light. The fire extended into the walls of the bathroom on the third floor. The apartments on the right side of the building on the first, second, and third floor, are uninhabitable due to smoke, water, and fire damage. This leave roughly 10 occupants displaced. This fire is classified as accidental.

Civilian Injuries: None

Emergency Service Injuries: None

Special Circumstances: 3 story wood framed , flat top, 6 unit occupied apartment building. Early morning fire, most building occupants were at home at time of fire. Freezing rain created slip and fall conditions.

Incident Commander: Battalion Chief Robert Beaudet

100 Merrimack Street • Manchester, NH 03101 • Telephone (603) 669-2256 • Fax: (603) 665-6802
www.ManchesterNH.gov